IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wade Henderson DATE 8-1-78 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 70 East TR on 2318 cross 3rd Creek TR 1/2 mi on right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 4+5 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other 2 mobile Homes Part in fill

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area 13 acres

Character & Porosity of Soil Cecil clay + Appling
Percolation Rate Sev.
Topography Rolling
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 1350 Linear Ft. 450
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by SCIS installed

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-1-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold