IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Patrick Speece DATE 04-15-82 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 70 to Shiloh Church Rd, cross 3rd Creek, 1/2 mile on right dirt drive S. R. No.

SUBDIVISION NAME Henderson MHP LOT NO. #9 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1 1/2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil & Appling clays (some parent materia

Percolation Rate 30 min/in


Topography 2 to 6% Slope

Depth to Water Table 10+

Rock or other impervious formations none

Lot Area 1/2 acre

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Charlie Moore

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY

COMMENTS: Septic tank system is functioning properly at time of inspection

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: Jerry L Price DATE 04-15-82

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold