DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CYNTHIA MORRIS APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: CORNER OF SHILOAH & CLEMENTZ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	4% LSS	0-3"	scl, wk, gr	fr, ns, np, sscp	yellow BROWN MOTTLES 3"-32"	748"			PS .25 .3
		3-24"	c, med, abk	fr, s, p, sscp					
		24-48"	c, med, abk/sbk	fr, s, p, sscp					
2	6% LSS	0-3"	scl, wk, gr	fr, ns, np, sscp	yellow BROWN mottles 3"-32"	748"			PS .25
		3-24"	c, med, abk	fi/fr, s, p, sscp					
		24-48"	c, med, abk/sbk	fr, s, p, sscp					
3	7% LSS	0-3"	scl, wk, gr	fr, ns, np, sscp	yellow BROWN mottles 3"-32"	>48"			PS .25
		3-24"	c, med, abk	fi, s, p, sscp					
		24-48"	c, med, abk/sbk	fr, s, p, sscp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	CONVEN	CONVEN
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: _____