DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Craig Deal APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 7-25-05
PROPOSED FACILITY: Duplex PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: 4.2 Ac
LOCATION OF SITE: 70 E TR Shiloh TL Clements on RT PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3-5%	0-25	1 sbk/abk C	fr SS/sp SE		48			.3
		25-48	1 sbk cl + sap	Cr SS/sp SE					
2		0-15	1 sbk/abk cl	fr SS/sp SE		48			.3
		15-40	1 sbk/abk C	fr SS/sp SE					
		40-48	1 sbk/cl + sap	fr SS/sp SE					
3		0-20	1 sbk/abk cl	fr SS/sp SE		48			.3
		20-30	1 sbk/abk C	fr SS/sp SE					
		30-48	1 sbk/abk cl sap						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	Yes
System Type(s)	25% red.	LP Panel
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Judy Melville