This Permit replaces previous one issued [illegible]

EDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PERMIT # 203909

PIN # 4752857173

LICANT: Deborah Jakielski APPLICANT ADDRESS: ~~[illegible]~~ 213 Winding Arbor Ct

E ADDRESS: 144 Crestview Rd. PHONE: 704-462-4104 ALT. PHONE: N/A

TE DIRECTIONS: Hwy 706 TR Shiloh Rd TL Clements TL Crestview Acres Property on Right

UBDIVISION: Crestview Acres SECTION: 1 LOT # 42 LOT AREA: 0.62 acres DESIGN FLOW: 360gpd L.T.A.R.: 0.25

Septic Tank 1000 (gal) STB 166-1000 Date 10-3-14

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 4 Linear Ft: 360

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

Comments / Conditions: Install a 25% Reduction system on contour with serial distribution.

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% Reduction

Repair System Description: 50% Reduction

Maintenance Agreement Required: ☐ YES ☑ NO

☑ GRAVITY ☐ PRESSURE

☑ Residence ☐ Business ☐ Other ☐ Slab ☐ Basement w/plumbing

No. Bedrooms 3 No. Persons 6 No. Employees

☑ Crawl Space ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

INITIAL SITE SKETCH



AS BUILT SKETCH

- Red Taylor Silver installed
- 2" PVC ST. marks installed
- Quick 4 chambers installed
- Installed as drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCA

☐ IMPROVEMENT PERMIT with plat valid without expiration.

☑ IMPROVEMENT PERMIT with site plan valid for 60 mos.

☑ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT--not to exceed

Signature: Deborah Jakielski Date: 20-Jun-14

Installed by: Shane Parrott Grading & Hauling Date: 12-

OPERATION PERMIT by: Justin Henderson Date: 6-19-14

Existing System Inspected by: 6-19-14

[illegible] (Conditional Approval) - PINK