IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tommy Lapish DATE 5/23/79 PERMIT NO.

PHONE: Business Home

LOCATION 70E, T.R. on 2318 (Stinkbell Church Rd.), cross 3rd creek, T.L. on 2358 1st on dirt road, 1st drive at end, across from Lakeview Baptist Ch. S. R. No.

SUBDIVISION NAME Crestview Acres LOT NO. 22+23 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1 acre

Character & Porosity of Soil Fair Good clay + Coarse Mat
Percolation Rate 45 min/inch
Topography 4% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Gentry

IMPROVEMENTS PERMIT BY J. G. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 5/22/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold