IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR H. A. Adams DATE 9-27-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E. TR on Rd 2318 - Barnard. TL on Rd 2318 - TR on 1st dirt street TL 1st Street - 2nd Mobile Home on Rt. S. R. No. _____

SUBDIVISION NAME Lloyd Adams LOT NO. 18 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____ Rent Trailer

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 100 X 200

Character & Porosity of Soil Common
Percolation Rate Good
Topography 2-6% Slope
Depth to Water Table Deep
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Satterwhite

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 9/27/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold