DIVISION OF ENVIRONMENTAL HEALTH

COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bob Esters OWNER: AGENT: PHONE:

ADDRESS: APPLICATION DATE: DATE EVALUATED:

PROPOSED FACILITY:

PROPERTY SIZE:

LOCATION OF SITE:

WATER SUPPLY: On-Site Well____ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring___ Pit___ Cut__

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1945 CLASS OF HORIZ	1945/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear 6%	0 to 6	L GR		PS	PS	PS	PS	.3
		6 to 48	C SBK	SEAP FR					
2	Linear 6%	0 to 6	L GR		PS	PS	PS	PS	.35
		6 to 24	C SBK	SEAP FR					
		24 to 48	SCL WSBK	NEAP FR					
3									
4									
5									

AVAILABLE SPACE (.1945): SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .133

EVALUATED BY: J. C. Moore OTHER(S) PRESENT: Bob Esters

COMMENTS: