IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Icenhour Bldg. Co. DATE 10-22-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E - Turn Rt on Rd - 2354 just past St. Pauls Lutheran Ch. 60 ¾ mile House on Left - Lot # 7+8 S. R. No. 2354


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Good
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	None
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Unknown
			Rock or other impervious formations	No

Lot Area 1½ Acres.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 240
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Icenhour Bldg. Co
Statesville, N.C.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Ivey Jr. DATE 10-25-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold