IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR L. A. Weis Enterprises DATE 19 Dec 73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Suburban Acres - Lot # 8

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area _____

Character & Porosity of Soil Red Clay
Percolation Rate none
Topography Slope to Rear
Depth to Water Table 12"
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 221'
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Collier County

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trench down grade to rear of House.

CERTIFICATE OF COMPLETION BY William A. Howard DATE 19 Dec 73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold