## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR LAKEVIEW Enterprises DATE 2-12-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Highway 70 E Rt on Rd # 2354 - House on Left before Rd # 2451 S. R. No. 2354

SUBDIVISION NAME Suburban Acres LOT NO. 3 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes ( ) | No (✓) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Lot Area 20,000

Character & Porosity of Soil Md Red Clay must
Percolation Rate _____
Topography Level must
Depth to Water Table _____
Rock or other impervious formations _____




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Young & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Todd Jr. DATE 2/12/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold