03070

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wayne Church DATE 5-14-85 PERMIT NO.

PHONE: Business Home

LOCATION TR 2 TR on Third Creek Rd T. on Sigmon Dr. Go approx ½ mi on Rt.

S. R. No.

SUBDIVISION NAME Sunnybrook Acres LOT NO. 7 SECTION OR BLOCK NO. 1

House ( ) Mobile Home (✓) Business ( ) Other


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay
Percolation Rate 4 Bal/Ss/Rocks
Topography Rolling
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 20,000 SF

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1000 Gals

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by James Hulley

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ___

IMPROVEMENTS PERMIT BY D. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 5-14-85

EXISTING SYSTEM CHECKED BY: ___ DATE ___

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

White Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

MAY. 28, 19;5 5:05