IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Shayne Page DATE 5/10/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E, TB Suburban Acres, 1st rd. TR, 1000' on R.

S. R. No. _____

SUBDIVISION NAME Suburban Acres LOT NO. 123 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms	3	No. Bathrooms	1½	
Garbage Disposal Unit	Yes ( )	No	(✓)	
Auto. Dishwasher	Yes (✓)	No	( )	
Auto. Wash. Machine	Yes (✓)	No	( )	
Site Suitable	Yes (✓)	No	( )	

Lot Area _____


Character & Porosity of Soil Clay Loam

Percolation Rate 90'

Topography 2/4%

Depth to Water Table 10+

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Hoke Bro.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles D. Brooks DATE 5/10/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold