IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Milam DATE 04-08-86 PERMIT NO.

PHONE: Business Home 873-2352

LOCATION 70 East, TR on Oak Grove Rd, 7th House on left

SUBDIVISION NAME Suburban Acres S. R. No.

LOT NO. SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Ample

Character & Porosity of Soil Poor suitable
Percolation Rate 0.4 gal/ft²/day
Topography 2-6% Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank Existing-precast Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by

IMPROVEMENTS PERMIT BY Jerry L Pierce

COMMENTS: Tank pumped and new tee installed to feed new lines first.

CERTIFICATE OF COMPLETION BY Jerry L Pierce DATE 04-08-86

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold