IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tony Brewer DATE 9-13-76 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 70E TR on Rd #2318 - Go Approx 3/4 Mile TR into Homestead Estate Houses 1st and 2nd St. on left S. R. No. _____

SUBDIVISION NAME Homestead Estates LOT NO. 11-12 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sand
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slopes to Back - Rt Side
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Good
Lot Area 1½ Acre			Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by ~~Yoke Septic Tank Service~~

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 9/13/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold