# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR WAYNE PIKE KENNETH HALL DATE 12-16-24 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70E Rt on Rd #2318 (Shiloh Ch. Rd) Rt. into Homestead Estates S. R. No. _____

SUBDIVISION NAME ~~Home Stead Estates~~ LOT NO. 4 & 5 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) |
| Auto. Dishwasher | Yes (✓) | No ( ) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Lot Area 1 ACRE


Character & Porosity of Soil Gray, Red Clay

Percolation Rate _____

Topography Slope to back

Depth to Water Table _____

Rock or other impervious formations None




Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd Jr. DATE 12/10/24

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold