IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Odell Bennett DATE 6/26/18 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70E, T.R. on Rd #2318, house on RT ¼ mile from Hwy 70

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. 2318 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	A & B
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Slow - mod
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	18"
			Rock or other impervious formations	none observed

Lot Area 4.94



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hobb Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: Indications of 2:1 clay - possible seasonal high water table

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 6/26/18

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold