IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mahaffey Bldg Co. DATE 7-3-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E TR on 2318 1/4mi on left

S. R. No. _____

SUBDIVISION NAME Beaver Farm LOT NO. 28 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 100X208

Character & Porosity of Soil Cecil Clay ✓
Percolation Rate 120 min/inch
Topography 2 to 6 %
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Robert Hoke

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: landscape & pipe Gutters so that surface water will not run into area of System

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 7-3-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold