IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR United Builders DATE 6-6-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E. TR on Rd 2318 House on left. S. R. No. 2318

SUBDIVISION NAME Beanes Farm LOT NO. 26 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	✓	No	( )
Auto. Dishwasher	Yes	✓	No	( )
Auto. Wash. Machine	Yes	✓	No	( )
Site Suitable	Yes	✓	No	( )

Lot Area _____


Character & Porosity of Soil CFB's

Percolation Rate Good

Topography 2 - 6% Slopes

Depth to Water Table deep

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Eddie Young & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Fox Jr. DATE 6/6/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold