IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roby Houston DATE 5-24-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E. TR on Rd # 2318

S. R. No. _____

SUBDIVISION NAME Beaver Farm LOT NO. 24 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 100-209 Approx


Character & Porosity of Soil CMB2

Percolation Rate Med

Topography 2-6% Slope

Depth to Water Table ---

Rock or other impervious formations ---



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 252 Linear Ft. 264
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 5/25/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold