IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Building Inc DATE 11-9-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 702 + Ben Rd 2318-


SUBDIVISION NAME Beaver Farm LOT NO. 23 SECTION OR BLOCK NO. _____ S. R. No 23A

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Less Than
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level to Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	None
			Rock or other impervious formations	None

Lot Area 20,000



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 756 Linear Ft. 252
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Hope Bros Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 11/9/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold