IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Dishmon DATE 2-25-80 PERMIT NO.

PHONE: Business Home

LOCATION 70 E

S. R. No.

SUBDIVISION NAME Beaver Farm LOT NO. 57 SECTION OR BLOCK NO.


House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 1/2 acre

Character & Porosity of Soil Appling/Clay
Percolation Rate 120 min/inch
Topography 2 to 4% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Don Lackey

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: landscape so water will not stand over lines

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 2-25-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold