IREDELL COUNTY HEALTH DEPARTMENT

SEPTIC TANK IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(General Absorption Sewage Disposal System — G.S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harrison McArdle DATE 5-12-83 PERMIT NO. _____

PHONE Business _____ Res. _____

LOCATION 7C E TR on 1st St. before Statesville Concrete on L in Curve S.P.N. _____

SUBDIVISION NAME Beaver Fm LOT NO. 60 SECTION OR BLOCK NO. _____

Property is: Mobile Home ( ) ✓ Other _____

No. Bedrooms 3 No. Baths 1½ Classification & Percolation Rate Clay (Class IV-A) 45 gal/55 sq ft/day

Garbage Disposal Unit: Yes ( ) No ✓ Topography 2% to 6%


Auto. Dishwasher: Yes ( ) No ✓ Depth to Water Table 10'+

Auto. Wash Machine: Yes ✓ No ( ) Rock or Impervious Formation None

Site Suitable: Yes ✓ No ( )

Area 1½ acres

( ) Basement with Plumbing ( ) Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Specification Field:
No. of Lines 4
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ✓
Public ( )

Prepared by Roger Sigmon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed _____

Form Signed

IMPROVEMENTS PERMIT BY J. C. moore

COMMENTS _____

CERTIFICATE OF COMPLETION BY J. C. moore DATE 5-12-83

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Improvements Permit Copy: Yellow Contractor's Copy: Pink Owner's Copy: Gold

JAN. 7, 1989 18:47