7456

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. DATE 12-8-88 PERMIT NO. B-15

PHONE: Business _____ Home _____

LOCATION Lot 38 Beaver Fm
70E TR on Beaverbrook Rd 1st Rd on Rt after Shiloh ch Rd S. R. No. _____

SUBDIVISION NAME Ness TR on Sevenoaks Rd LOT NO. _____ SECTION OR BLOCK NO. _____
house on left


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey
Percolation Rate .36
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations modling 36"+042"

Lot Area 100'X300'

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 15"
Water Supply: Individual (✓)
Public ( )

Installed by Arnie Duncan

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 12-8-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold