01352

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. DATE 10-25-84 PERMIT NO.

PHONE: Business Home

LOCATION 70 E before Statesville Concrete on Rt.

SUBDIVISION NAME Beaver Fm LOT NO. 6 S. R. No. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 100' X 200'

Character & Porosity of Soil Clay


Percolation Rate 14 sec/55" / clay

Topography 2 to 6%

Depth to Water Table 10'+

Rock or other impervious formations none

Basement with Plumbing Basement without Plumbing No Basement (✓)



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Arnie Duncan

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY

EXISTING SYSTEM CHECKED BY: L. C. Moore DATE 10-25-84

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold