IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

IER OR CONTRACTOR Ivetell Fiber DATE 3-18-88 PERMIT NO.

NE Business Home

ATION Carrier Fan Jay rt + Hwy 70 behind S. R. No.
Eletsin Industries

DIVISION NAME LOT NO SECTION OR BLOCK NO.


e ( ) Mobile Home ( ) Business (✓) Other 30 Employees

Bedrooms No. Bathrooms
bage Disposal Unit Yes ( ) No ( )
Dishwasher Yes ( ) No ( )
Washing Machine Yes ( ) No ( )
Yes ( ) No ( )

Character & Porosity of Soil Clayey
Percolation Rate 35 gal/sq ft/day
Topography Hilly
Depth to Water Table 10 ft
Rock or other impervious formations none

Basement with Plumbing Basement without Plumbing No Basement

Size of Tank 1500 Gals.
Nitrification Field
No. of Lines 5
Sq. Ft. 210 Lineal Ft. 700
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)



Installed by J.C. Forth

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed

Plot or System

J. C. moore

J. C. moore DATE 3-18-88

DATE

COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Location of system and any false information is subject to misdemeanor

Health Dept. Copy White Inspection Dept. Copy Yellow Sanitarian's Copy Pink Owner's Copy Gold

"POOR QUALITY