IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J.L. Hope Sr. DATE 9-26-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1842 Sasviet Rd S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1/2 acre+

Character & Porosity of Soil Cecil Sandy clay
Percolation Rate 45 min/inch
Topography 4% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 1 into 2
Sq. Ft. 810 Linear Ft. 270
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hope Brother

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: new Tee, installed came out at side at front of Tank.

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 9-26-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold