IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers Blds DATE 28 July 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. & Sapsuit Rd. on Rgt. Go to 3rd street on rgt. Go to 2nd street on rgt. Home at end of street on Rgt. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Marginal Clay at end of drain field
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	slow
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	2'
			Rock or other impervious formations	2'

Lot Area 30,000 sq ft



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 230
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 28 July 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold