IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Federle DATE 12-28-78 PERMIT NO.

PHONE: Business Home

LOCATION 2020 Crouch Circle

S. R. No.


SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	70 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area acreage



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )

Set 480 gal Pump Tank

Installed by Don Lackey

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Set Pump so that it can be disconnect easily & worked on if need be. Also provide easy access to Pump. Set Float so will Pump approx 250 gal at one time.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 12-28-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold