IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. DATE 9/2/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Beauty St

S. R. No. _____

SUBDIVISION NAME Glen Gary LOT NO. 56 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____


Character & Porosity of Soil Clayey

Percolation Rate ok

Topography 6-10%

Depth to Water Table ok

Rock or other impervious formations possible



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1030 Linear Ft. 730

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: If lot 57 is sold, a easement for sewage system must be recorded. Lot #57 not suitable for building at this time.

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 9/2/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold