IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roger Lee Scott DATE 3-29-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1209 Sterling St (Rt no. 2424) off Murdock Rd.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area _____

Character & Porosity of Soil Appling Clay
Percolation Rate 120 min /inch
Topography 2 to 3% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Existing
Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 150
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by William Culbertson

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: divert all surface water from area where lines are located.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-29-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold