IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Josephine Maxwell DATE 3-31-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1207 Sterling St 055 murdock Rd

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil clay
Percolation Rate 100 min/inch
Topography 2 to 4 %
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 15,000 sq'



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by William Culbertson

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Pipe all gutters + landscape so water will not stand over lines

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 3-31-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold