IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Middleton DATE 5-2-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. TR on Joe Rd 2nd Jct TR 1 block TL on Beauty St 2nd house on left S. R. No. _____


SUBDIVISION NAME 2111 Beauty St. LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	120 min 1 inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	20% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'	
			Rock or other impervious formations	None	

Lot Area 17000 Sq'



Plot of System

Size of Tank Existing 1000 Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 450 Linear Ft. 150
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Ettie Yountz

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 5-2-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold