IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR United Builders DATE 11-22-77 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Beaty St.

SUBDIVISION NAME Jax Jay LOT NO. 90 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Stor. Sentina

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	CTS L
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level to Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Under 1 Foot
Lot Area _____			Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 777 Linear Ft. 257

Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Edwin Fox Jr. DATE 11-22-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold