IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR United Builders DATE 2/24/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Beauty St S. R. No. _____

SUBDIVISION NAME Jean Gray LOT NO. 92 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____ Prov. Suitable

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area _____

Character & Porosity of Soil CfCl
Percolation Rate Mod
Topography 2-6%
Depth to Water Table und
Rock or other impervious formations und



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 870 Linear Ft. 290
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Arnie Duncan

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Craig DATE 2/24/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold