IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harold D. Turnmire DATE 9-27-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad EXT. TR on Joe Road
2116 Joe Road S. R. No. _____

SUBDIVISION NAME Jan Joi LOT NO. 77 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Red Clay
Percolation Rate 90 min / inch
Topography 2% Slope
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 100 X 160



Plot of System

Size of Tank Existing 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Brothers
Arnie Duncan

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Keep Proposed Swimming Pool 15' from nitrification Lines or Septic Tank

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 9-27-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold