IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Johnny Hope DATE 9/15/79 PERMIT NO.

PHONE: Business Home

LOCATION Beauty Street off East Broad St.


S. R. No.

SUBDIVISION NAME Star Boy LOT NO. 94 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay Loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'	
Lot Area 17000 sq ft			Rock or other impervious formations	none	



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 700 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: 3 Bdrm House stub-out too deep

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 9/15/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

3' x 55'

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold