IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Henkins Bldg. Co. DATE 7-22-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Lucille St. _____

_____ S. R. No. _____

SUBDIVISION NAME Jan Joy LOT NO. 78 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 187 X 100


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slope to front

Depth to Water Table _____

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public (✓)

Installed by Henkins Bldg Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: House started prior to time Septictanks stick out at front of house and Nitrification field 7' deep at the end.

CERTIFICATE OF COMPLETION BY Glenn Ford Jr. DATE 7/22/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold