IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Church of God DATE 9-25-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 2308 East Broad St.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other 200 member Church

No. Bedrooms _____ No. Bathrooms 6

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil Clay

Percolation Rate 1 5gal / Sq ft / Hr


Topography 2 to 6% Slope

Depth to Water Table 10'+

Rock or other impervious formations none

Lot Area 4.12 acres

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 1800 Linear Ft. 600
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 9-25-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold