HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Hope Bros OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 2-9-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	
1	2 to 4%	0 to 6"	b	GR		.1942 WETNESS CONDITION - N/A
		6 to 48"	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	6 to 8%	0 to 5"	b	GR		.1942 WETNESS CONDITION - N/A
		5 to 48"	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) YES SITE CLASSIFICATION (.1945): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: OTHER(S) PRESENT: John Lee Hope
COMMENTS:

DRAFT