IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Ellison DATE 6-30-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Freedom Drive 1/4mi on L from S. Greenbrair S. R. No. _____

SUBDIVISION NAME Freedom Drive Develop. LOT NO. 1/2 32 & 41 33 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil _____
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate _____
Auto. Wash. Machine	Yes (✓)	No ( )	Topography _____
Site Suitable	Yes (✓)	No ( )	Depth to Water Table Existing
			Rock or other impervious formations System

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros 1977

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: L. C. Moore DATE 6-30-83

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold