IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros Builders DATE 1-27-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION N/W corner Freedom Dr and Abernathy Ave

S. R. No. _____

SUBDIVISION NAME King St. LOT NO. 101 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 94 x 150 approx

Character & Porosity of Soil Cecil Clay
Percolation Rate 1 inch
Topography Slopes Back
Depth to Water Table +10
Rock or other impervious formations none



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: North West Corner of drainfield not in undisturbed soil area should be graded a distance of 15' plus and at least 20" of clean sand area

CERTIFICATE OF COMPLETION BY Glenn Fry Jr. DATE 1/27/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold