## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros Builders Inc DATE 2-21-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bellette Ave

S. R. No. _____

SUBDIVISION NAME King St. LOT NO. 104 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes ( ) | No (✓) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Lot Area 100 X 150

Character & Porosity of Soil Sandy Clay
Percolation Rate Low-Mod
Topography 10-14% Slope
Depth to Water Table 4ft
Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 3/21/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold