## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros Builders Inc DATE 2-18-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Collette Ave. King St. Extension

S. R. No. _____


SUBDIVISION NAME King St LOT NO. 105 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Cecil Red Clay | |
| Auto. Dishwasher | Yes ( ) | No (✓) | Percolation Rate | 1 min | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | Rise to back 25ft | |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | | |
| | | | Rock or other impervious formations | none | |

Lot Area 15,000




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Entire Nitrification Should be covered with at least 18" soil about it can get shallower - Divert all downspout away from drainfield

CERTIFICATE OF COMPLETION BY Glenn Ford Jr. DATE 2/18/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold