IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Song Won NamKung DATE 10-15-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broat St TR on Joe Rd TL on Council Ave house on left S. R. No. _____


SUBDIVISION NAME Jan Joy LOT NO. 64 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 min/inch 5 to 120
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 175' X 100'



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public ( )

Installed by Don Lackey

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: landscape & pipe Gutters so water will not stand over Tank or lines.

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-15-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold