IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Gatton DATE 6-25-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 332 Toria Drive

S. R. No. _____

SUBDIVISION NAME Dal Wan Heights LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	( )	No	(✓)	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil Cecil clay
Percolation Rate 50 min/inch
Topography 2 to 6 % Slope
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 18,000 sq'



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 270 Linear Ft. 93
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: * very important to pipe Gutters & landscape so that water will not stand over lines. Excess surface water that runs into area at end of house will fail system unless it is run off

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 6-25-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold