IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Nelson Bass DATE 8/17/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad East, TR on Tara Dr., T.L. on Walton Dr., last house on left (403 Walton Dr. S. R. No. _____

SUBDIVISION NAME Dalwan LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area _____

Character & Porosity of Soil Red clay
Percolation Rate none
Topography rolling
Depth to Water Table 6ft
Rock or other impervious formations none observed

Repair



Plot of System

Size of Tank existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 498 Linear Ft. 166
Depth of Stone in Lines 18-20"
Water Supply: Individual ( )
Public ( )

Installed by Eddie Young

IMPROVEMENTS PERMIT BY _____

COMMENTS: Washer lines not installed

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 8/17/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold