IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Boyt DATE 5-4-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad [redacted]

S. R. No. _____

SUBDIVISION NAME Eastfield LOT NO. 13-16 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil LBC 2
Percolation Rate Est. 90 min
Topography 6 to 10%
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area .9 acres



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz + Son.

IMPROVEMENTS PERMIT BY Glenn FOX.

COMMENTS: landscape so that surface water does not stand over Tank or lines.

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 5-4-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold