IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Johnny Johnson DATE [redacted] 4-6-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad Ext. 1/4 mi before creek on right

S. R. No. _____

SUBDIVISION NAME East Field LOT NO. 17-20 SECTION OR BLOCK NO. A
Lot 10 on Platt


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 100 X 178

Character & Porosity of Soil Soft Parent material
Percolation Rate less than 45 min/inch
Topography 2% Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 4-6-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold