IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ann R. Scott DATE 12-22-82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 2406 E. Greenbrier Rd.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Red clay loam
Percolation Rate 0.5 gal/ft²/day
Topography 2 to 7% slope
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 90' x 70'

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 7
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Wm. Culbertson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: 3 step downs

CERTIFICATE OF COMPLETION BY Jerry L Price DATE 12-22-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold